




The State of New Hampshire  
***Department of Environmental Services***



**Michael P. Nolin**  
Commissioner

LETTER OF DEFICIENCY

No. WD SS 06-009

June 26, 2006

Royden Haskins  
Tammy Dukette  
230 King Street  
Boscawen, NH 03303

RE: Septic Effluent from Pipe in Rear of Property

Dear Mr. Haskins and Ms. Dukette:

On June 16, 2006 personnel from the Department of Environmental Services, Water Division ("DES") conducted an inspection of property bordering your property on King Street, described as Lot # 7, on Tax Map # 81-A, and located on King Street, Boscawen, NH, 03303 ("the Property"). The purpose of this inspection was to determine whether you were in compliance with RSA 485-A and its implementing regulations, the Subdivision and Individual Sewage Disposal System Design Rules, Env-Ws 1000 ("the Rules").

As a result of the inspection, the following deficiency was noted:

1. A pipe exiting the hillside on your property is emitting septic effluent down the hill on your property and your neighbor's property.

DES believes the above deficiency can be permanently corrected within 30 days by initiating and completing the following measures:

1. Engage a permitted septic system designer to prepare and submit septic system plans and specifications to DES for the total waste load generated on the Property.
2. Obtain approval to construct the system.
3. Construct and obtain approval to cover and use the system.
4. Operate and maintain the system in accordance with NH Administrative Rule Env-Ws 1023.

**During the interim between receipt of this letter and the date by which permanent corrections have been completed, as an alternate to vacating the premises, DES requests that collected sewage be pumped and disposed in accordance with NH Administrative Rule Env-Ws 1600 at sufficient frequent intervals to prevent further overflow. If this alternative is utilized, it is requested that pumping receipts be retained.**

DES believes the cited deficiencies can be corrected within 30 days and a report describing the corrective measures can be submitted to this office within 30 days of receipt of this letter.

In the event compliance is not achieved within this period, DES may initiate further action against you, including issuing an order requiring the above items to be corrected and/or referring the matter to the New Hampshire Department of Justice for imposition of civil and/or criminal penalties. DES reserves the right to pursue administrative fines for the violation(s) noted above.

The written report as requested above should be addressed as follows:

Richard J. de Seve, SSB, DES  
Department of Environmental Services  
6 Hazen Drive, PO Box 95  
Concord, NH 03302-0095

Your prompt cooperation is appreciated. Should you have any questions regarding this letter, please contact Richard J. de Seve at 271-3442.

Sincerely,



William E. Evans, P.E.  
Administrator  
Subsurface Systems Bureau

WEE/RJD

**CERTIFIED MAIL 7099 3400 0002 9772 9806**

Cc: James G. Falicon, SSB, DES  
Gretchen Hamel, Administrator, DES Legal Unit  
Board of Selectmen, Town of Boscawen  
P. Mitchell, Health Officer, Town of Boscawen  
Richard J. de Seve, SSB, DES